



Fire Alarm Systems Plan Review

Fire Alarm Plan

- Check for proper License and Insurance.
- Design documents are signed and sealed.
- Reference to NFPA 72 and 70.
- Location of FACP or annunciator panel clearly accessible/visible from entry.
- Smoke detector located at panel.
- Point to Point wiring, EOL device shown.
- Proper spacing/coverage/location of spot detectors (heat & smoke).
- Proper spacing/coverage/location of beam detectors.
- Proper location of duct detectors.
- Proper spacing and location of pull stations.
- Proper location of detectors associated with door holders.
- Proper location of detectors associated with stair pressurization.
- Proper spacing/coverage/location of notification appliances.
- Add condition that audible notification be checked during inspection.
- Sprinkler flow switches monitored.
- Sprinkler tamper switches monitored.
- Fire pump monitored.
- Battery calculations.
- Device legend.
- Fla. Accessibility notification requirements met.
- Emergency forces notification.
- Elevator control room, shaft, and recall.
- Special systems, VESDA, etc.
- Apartment smoke/CO detectors, every floor-bedrooms-sleeping area (hallway).
- Show smoke evacuation sequence of operation.
- Knox Box in location approved by AHJ.

This document is intended to be a guide and may not contain all requirements needed to obtain permits and approval from the City of DeLand.